

IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:

IECEx SIM 14.0007X

Issue No: 0

Certificate history:

Issue No. 0 (2014-07-18)

Status:

Current

Page 1 of 3

Date of Issue:

2014-07-18

Applicant:

CMP Products Ltd

Glasshouse Street

St Peters

NEWCASTLE UPON TYNE

NE6 1BS United Kingdom

Electrical Apparatus:

Cable Glands Type E** and Triton Types T3** and TE**

Optional accessory:

Type of Protection:

Flameproof, Increased Safety, Restricted Breathing and Dust Protection by Enclosure

Marking:

Ex e I Mb Ex d I Mb Ex e IIC Gb Ex d IIC Gb Ex nR IIC Gc Ex ta IIIC Da

 $Ta = -60^{\circ}C$ to +130°C (When fitted with the standard seal)

Ta = -20°C to +200°C (When fitted with the high temperarture seal)

Approved for issue on behalf of the IECEx

Certification Body:

Geoffrey Barnier

Position:

00,...

Principal Engineer - Certification

Signature:

(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

Safety in Mines Testing and Research Station (Simtars)
2 Smith Street
REDBANK QLD 4301
Australia



18 July 2014



IECEx Certificate of Conformity

Certificate No:

IECEx SIM 14.0007X

Issue No: 0

Date of Issue:

2014-07-18

Page 2 of 3

Manufacturer:

CMP Products Ltd 3 Nelson Way Nelson Park East CRAMLINGTON NORTHUMBERLAND

NF23 1WH United Kingdom

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Explosive atmospheres - Part 0: General requirements

Edition:6.0

IEC 60079-1: 2007-04

Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"

Edition:6

IEC 60079-15: 2010

Explosive atmospheres - Part 15: Equipment protection by type of protection "n"

IEC 60079-31: 2008

Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure 't'

Edition:1

IEC 60079-7: 2006-07

Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

Edition:4

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/SIR/ExTR13.0066/00

Quality Assessment Report:

GB/SIR/QAR07.0009/05



IECEx Certificate of Conformity

Certificate No:

IECEx SIM 14.0007X

Issue No: 0

Date of Issue:

2014-07-18

Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The E** series Type ranges of cable glands consist of a male-threaded front entry component containing an elastomeric sealing ring and a Nylon 6 skid washer which effect flameproof sealing onto the cable inner sheath and is intended to screw into an entry point of its associated enclosure in accordance with relevant codes of practice. The flameproof seal is actuated by an adjoining coupling component. The coupling component is attached to a main body. Their mating thread may be fitted with an optional 'O' ring seal to provide increased ingress protection. Clamping of the armoured or braided cable is effected by a combination of the coupling component, main body and the different optional armour cone and armour sleeve combinations being fastened together. An outer seal nut, containing an elastomeric sealing ring and a Nylon 6 ferrule, threads onto the main body and effects environmental sealing onto the cable outer sheath.

T3CDS - a range of displacement type cable glands, each comprises of a hollow threaded entry component containing an elastomeric compensating displacement seal (CDS) system with associated ferrule, a skid washer, flameproof sealing ring with compensator, a clamping sleeve and armour cone are provided for termination of various armour types. The flameproof sealing assembly is actuated by an inner seal nut. The entry component is fitted with an 'O' ring seal to provide increased ingress and deluge protection. Clamping of the armoured or braided cable is effected by a combination of the entry component, main body and the different optional armour cone and armour sleeve combinations being fastened together. An outer seal nut, containing an elastomeric sealing ring and a Nylon 6 ferrule, threads onto the main body and effects environmental sealing onto the cable outer sheath. The glands are intended for use with appropriately sized SWA, P.W.A., strip armoured, tape armoured or braided cables. The design is such that a constant pressure is maintained on the displacement seal by the use of the compensation ferrule.

T3CDS/PB Identical to the T3CDS Type but incorporates a continuity washer and are suitable for use with lead sheathed cables.

TE1F* Type - Identical inner seal/armour clamp front/outer seal to the T3CDS Type but overall length is shortened. The glands are intended for use with appropriately sized SWA, P.W.A., strip armoured, tape armoured or braided cables.

CONDITIONS OF CERTIFICATION: YES as shown below:

The E**-Type cable glands shall not be used on braided cables in group I applications.

The T3** and TE** Type cable glands shall not be used to terminate on braided cables in Equipment I Protection Level Mb applications.

The glands when used for terminating braided cables are only suitable for fixed installations. Cables must be effectively clamped to prevent pulling or twisting.

When assembled for fitting to flexible conduit, the conduit shall be effectively clamped to prevent twisting and pulling.

Annex:

IECEx SIM 14.0007X-0 Annex.pdf